

PRETREATMENT MONITORING REPORT

Name: CARIBE INTERNATIONAL LLC

Mailing Address: 452 EAST 22nd STREET, PATERSON, NJ 07514

Facility Location: 452 EAST 22nd STREET, PATERSON, NJ 07514

Category & Subpart: 40 CFR 403 Outlet#: 1

Contact Official: Rene Quiroz Telephone#: (973) 569-0155

CUSTOMER ID / OUTLET ID: 27220160-1

*** ZERO DISCHARGE ***

*** ENTER ONLY ***

MONITORING PERIOD						AVERAGE	MAXIMUM
01	1	2009	01	31	2009		
MON	DAY	YR	MON	DAY	YR		
START			END			Method Used: PVSC Local Limit Regulated Flow determined from readings of incoming water meter minus internal process meter (water to product) – 5% evaporation, divided by 22 work days. Maximum = Average + 25%	
Cd	Sample measurement						
	Permit requirement					0.19	N/A
Cu	Sample measurement						
	Permit requirement					3.02	N/A
Pb	Sample measurement						
	Permit requirement					0.54	N/A
Hg	Sample measurement						
	Permit requirement					0.08	N/A
Ni	Sample measurement						
	Permit requirement					5.9	N/A
Zn	Sample measurement						
	Permit requirement					1.67	N/A
	Sample measurement						
	Permit requirement						
	Sample measurement						
	Permit requirement						
	Sample measurement						
	Permit requirement						

PRETREATMENT MONITORING REPORT**Certification of Non-use (use additional sheets if necessary) Based on Historical Data.**N/A


FEB 19 2009

Compliance or non-compliance statement with compliance schedule (use additional sheets if necessary) for every parameter used.Caribe International, LLC was in compliance with PVSC Local Limits for self monitoring performedduring this month and as presented in this report.**Explain Method for preserving samples:**Metal sample was a composite sample preserved with HNO₃ to a pH of < 2.0.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

403.6(a)(2)(ii) revised by 53 FR 40610, October 17, 1988

Signature of Principal
Executive or Authorized Agent


Rene Quiroz
Vice President
Type Name and Title

1/17-2009
Date

CARIBE INTERNATIONAL, INC. - MR-1 REPORT - Jan 2009

10 WORK DAYS IN MONTH

OUTLET #1**READINGS OF METER: OUTLET # 27220160-1**

1,408,850	Present Meter Reading
-1,408,700	Past Meter Reading
150	Cubic feet
x7.48	
1,122	Gallons Incoming for Outlet # 27220160-1

TANK CLEANING

97,560	Present Meter Reading
-97,372	Past Meter Reading
188	gals

INTERNAL WATER METER (USED FOR PRODUCT))

517,194	Present Meter Reading
-517,154	Past Meter Reading
40	Gallons in Product

103	GPD = AVG RegulatedFlow
10 1,028	Outlet#27220160-1

1,122	Gallons - Incoming from Meter #1
-40	Gallons for Water in Product
1,082	
x .95	(-5% evaporation)
1,028	Total Gallons Discharged at Outlet # 27220160-1

103	GPD = AVG RegulatedFlow
x 1.25	MAX = AVG + 25%
129	GPD = MAX RegulatedFlow

Caribe International
452 East 22nd Street
Paterson N.J. 07514

To Whom It May Concern, there was no production at our Paterson plant for the month of January 2009.

Best Regards
Rene Quiroz
Caribe International